

Emergency Lighting Routine Planned Maintenance

Single Point Emergency Escape Lighting Systems

Current British standard **BS:5266:1999** under Clause 12.4 requires the Owner/Occupier to carry out regular inspections as listed.

Daily: Record any defects and instigate repair

Monthly: Each luminaire to be energised via its battery to check illumination.

Half Yearly: Each luminaire to be energised via its battery for 60 or 15 minutes.

Annually: For luminaires that are three years or older. Each luminaire to be energised via its own battery for its rated standby duration.

A log should also be kept

For good general guidance see also

<http://www.cef.co.uk/technical/fire/index.html>